

FIRE SAFETY CERTIFICATE

No: 128/NOC/DFO/BELAGAVI/2023


Date: 16-06-2023

Certified that the **Vidya Prasarak Samiti's, Sri Veerabhadreshwar English Medium CBSE School, Godachi, Ramdurg Taluk, Belagavi District.** Comprised of **Ground & One Upper Floor** Owned/Occupied by **Sri Veerabhadreshwar English Medium CBSE School** have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the **District Fire Officer, Belagavi** Fire Service on **16-06-2023** in the presence of The Principal, **Sri. Chidanand Chilami** and that the Building/Premises is fit for occupancy upto classes **Xth** with effect from **16-06-2023 for a period of One Year** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Maintenance of all fire fighting installations periodically
- 2.
- 3.
- 4.

Issued on 16-06-2023 at Belagavi, by

*Strike out whichever is not applicable.

Signature with Seal : 
 Name : S.S. Nilgar
 Designation : District Fire Officer
 Name & Address : Office of the District Fire Officer
 of Department/Office : Office of the District Fire Officer
 Karnataka State Fire & Emergency
 Services, Khanapur Road, Near
 Goaves Circle, Belagavi-590001.

To,
 The Principal
 Sri Veerabhadreshwar English
 Medium CBSE School, Godachi,
 Ramdurg Taluk, Belagavi District.


PRESIDENT
 Vidya Prasarak Samiti, Ramdurg.


Principal
 Sri Veerabhadreshwar English
 Medium CBSE School GODACHI
 Tq: Ramdurg Dist: Belagavi

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....

.....

(Name and Designation of the authorized signatory)

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with original vernacular certificate as a single pdf.

Office of the District Fire Officer
Karnataka State Fire
and Emergency Services
Khanapur Road, Belagavi-590001



Phone : 0831-2429441
E-Mail : dfobgv@gmail.com

C.NO/128/NOC/DFO/BELAGAVI/2023

Date :16-06-2023

To,
The Principal
Sri Veerabhadreshwar English
Medium CBSE School, Godachi,
Ramdurg Taluk, Belagavi District.

Sir,

Sub : Issue of “NOC” to Vidya Prasarak Samiti’s, Sri Veerabhadreshwar English Medium
CBSE School, Godachi, Ramdurg Taluk, Belagavi District.

Ref: Applicant Request Letter Dated: 13-06-2023.

*_*_*_*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of **Vidya Prasarak Samiti’s, Sri Veerabhadreshwar English Medium CBSE School**, building consisting with Ground & 1 Upper floor situated at **Godachi, Ramdurg Taluk, Belagavi District** was inspected by me on 16-05-2023 with respect to NOC to the premises.

ANNEXURE-1

“GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.


01.	Name and Address of the Applicant	The Principal Sri Veerabhadreshwar English Medium CBSE School, Godachi, Ramdurg Taluk, Belagavi District.
02.	Name and Address of the Premises	Vidya Prasarak Samiti’s, Sri Veerabhadreshwar English Medium CBSE School, Godachi, Ramdurg Taluk, Belagavi District.
03.	Name and Address of the Building Owner	The President Sri. T. Damodar Vidya Prasarak Samiti Ramdurg Ramdurg Taluk, Belagavi District.
04.	Number of Building	01
05.	Number of Floors	Ground & 1 Upper Floor
06.	Floor-wise details of Occupancy:-	
	Ground Floor	Class Room-08, Computer Lab-01, Office-01, Staff Room-01, Store Room-01& Play Home Room-01.
	1 st Floor	Class Room-06 AV Hall-01, Science Lab-01, Library-01, Maths Lab-01, PE Room-01 & Management Room-01.
07.	Height of the building	06.80 mtr
08.	Site area	08 Acre 24 Gunta
09.	Built-up area of each floor:-	
	Ground Floor	877.71 Sq mtr
	1 st floor	877.71 Sq mtr

[Signature]
16/06/23

10.	Total Built-up area	1755.42 Sq mtr
11.	Surrounding properties:-	
	East	Open Land
	West	Open Land
	North	Open Land
	South	Road
12.	Open Space all around the building	
	East	05.60 mtr
	West	04.50 mtr
	North	04.50 mtr
	South	15.90 mtr
Allowed Setbacks (open space) should be maintained free from further obstruction/construction.		


B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

Sl. No	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	Accessibility from Southern side with 09.00 Mtr wide road		--
02.	Number of Entrances	01 entrance of 04.40 mtr wide.		--
03.	Number of Staircase	No of staircase	02. nos both are equal measures	Staircase should be free from any obstructions.
		Width of the staircase	01.70 mtr	
		Width of threads	0.30 mtr	
		Height of risers	0.15 mtr	
		No of risers per flight	12	
		Height of the hand drill.	0.85 mtr	
04.	Portable Extinguishers	06 nos. of 4 Kg capacity DCP type extinguishers & 01 CO ₂ has been provided. All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.		Complied
05.	Hose reel hose system	Two Hose reel hose have been provided one at each floor. The hose reel hose of min 19 mm size and of 30 mtrs length shall be provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size.		Complied
06.	At the terrace tank level with minimum	The system should be connected to an booster pump of 450 LPM or of 5 HP capacity.		Complied



Bisw
16/06/23

	pressure of 3.5 kg/cm ²	Further the system should be connected to an alternative source of power supply.	
07.	Diesel Generator	Diesel generator of 05 KVA capacity should be provided to supply alternative power supply.	Complied
08.	Terrace Tank	The system should be connected to an over head tank of 5000 ltrs capacity and is connected to the booster pump.	Complied
09.	Escape routes	Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.	Complied
10.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency has been displayed with the telephone numbers of Ramdurg Fire Station i.e 08335-241627 & 101, 080-22971550, 22971500, 22971600 and the telephone no's nearest ambulance services and police station.	Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board should be written in English & Kannada both languages shall be prominently displayed at inside the entry/exit of the each floor.	Complied
12.	Fire Siren	A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.	Complied
13.	Nominate One Fire Nodal Officer	Shri B.Y.Kankannavar has been nominated as the Fire Nodal Officer.	Complied
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.



16/06/23

15. Fire Precautionary Measures

A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.

B:- Accumulation of combustibile waste in and around the premises should be avoided.

C:- The Exit ways shall be always kept clear without any obstruction.

D:- Liquefied petroleum gas should not be stored in the building.


E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.

F:- During the class hours the class room door shall not be locked from inside to out side.

G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "NOC" to Vidya Prasarak Samiti's, Sri Veerabhadreshwar English Medium CBSE School, Godachi, Ramdurg Taluk, Belagavi District. subjected to maintenance of fire fighting installations periodically and the staff should get trained in the basic fire fighting at Training Centre R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "NOC" is valid for only one year from the date of issue and is renewable.



Yours Faithfully

[Signature]
District Fire Officer
Karnataka State Fire And Emergency Services
Belagavi-01.

[Signature]
PRESIDENT
Vidya Prasarak Samiti, Ramdurg.

[Signature]
**Sri Veerabhadreshwar English
Medium CBSE School GODACHI
Tq: Ramdurg Dist: Belagavi**